



THIS HOME'S SCORE **1** OUT OF 10

THIS HOME'S ESTIMATED ENERGY COSTS

\$3,036 PER YEAR

HOME PROFILE

LOCATION:

3640 SW Dosch Rd
Portland, OR 97239

YEAR BUILT:

1926

HEATED FLOOR AREA:

4,279 sq.ft.

NUMBER OF BEDROOMS:

6

ASSESSMENT

ASSESSMENT DATE:

11/17/2017

SCORE EXPIRATION DATE:

11/17/2025

ASSESSOR:

John DeLance
Advanced Comfort & Safety

PHONE:

503-704-2583

EMAIL:

mail@
acsinspections.com

LICENSE #:

179681

Flip over to learn how to improve this score and use less energy!



Home Energy Score



Official Assessment | ID# 179795

The Home Energy Score is a national rating System developed by the U.S. Department of Energy. The Score reflects the estimated energy use of a home based upon the home's structure and heating, cooling, and hot water systems. The average score is a 5. Learn more at HomeEnergyScore.gov.

HOW MUCH ENERGY IS THIS HOME LIKELY TO USE?

Electric: 13,220 kWh/yr. \$1,454
Natural Gas: 1,598 therms/yr. \$1,582
Other: \$0
Renewable Generation: (\$0)

TOTAL ENERGY COSTS PER YEAR \$3,036

How much **renewable energy** does this home generate?
 ____ kWh/yr

THIS HOME'S CARBON FOOTPRINT:



What should my home's carbon footprint be? Between now and 2030, Portlanders should reduce carbon pollution per household to 3 metric tons per year to reach our climate goals.

- Actual energy use and costs may vary based on occupant behavior and other factors.
- Estimated energy costs were calculated based on current utility prices (\$0.11/kwh for electricity; \$0.99/therm for natural gas; \$2.58/gal for heating oil; \$2.21/gal for propane).
- Carbon footprint is based only on estimated home energy use. Carbon emissions are estimated based on utility and fuel-specific emissions factors provided by the OR Department of Energy.
- Relisting 2-7 years after the assessment date requires a free reprint of the Report from us.greenbuildingregistry.com to update energy and carbon information.
- **This report meets Oregon's Home Energy Performance Score Standard and complies with Portland City Code Chapter 17.108.**

Score today:

1

Score with priority improvements:

1

Estimated energy savings with priority improvements:

\$261 PER YEAR

Estimated carbon reduction with priority improvements:

10% PER YEAR

TACKLE ENERGY WASTE TODAY!

Enjoy the rewards of a comfortable, energy efficient home that saves you money.

- Get your home energy assessment. Done!
- Choose energy improvements from the list of recommendations below.
- Select a contractor (or two, for comparison) and obtain bids.
Checkout www.energytrust.org/findacontractor or call toll free **1-866-368-7878**.
- Explore financing options at communityenergyproject.org or energytrust.org.
- Visit the following resources to learn about easy changes you can make today: communityenergyproject.org/services or energytrust.org/solutions/insulation-and-air-sealing/

PRIORITY ENERGY IMPROVEMENTS | 10 YEAR PAYBACK OR LESS

| FEATURE | TODAY'S CONDITION ³ | RECOMMENDED IMPROVEMENTS |
|------------------------|--------------------------------|---|
| Cathedral Ceiling/Roof | Roof insulated to R-0 | Insulate cathedral ceiling/roof to R-30 or maximum possible |
| Envelope/Air sealing | Not professionally air sealed | Professionally air seal |
| Solar PV | None | Visit www.energytrust.org/solar to learn more (Note: Solar PV is not included in "Score with Improve |

ADDITIONAL ENERGY RECOMMENDATIONS

| FEATURE | TODAY'S CONDITION ³ | RECOMMENDED IMPROVEMENTS |
|----------------------------|--------------------------------|--------------------------|
| Air Conditioner | None | |
| Attic insulation | Ceiling insulated to R-11 | |
| Basement wall insulation | None | |
| Duct insulation | Un-insulated | |
| Duct sealing | Un-sealed | |
| Floor insulation | Insulated to R-0 | |
| Foundation wall insulation | None | |
| Heating equipment | Natural gas boiler 94% AFUE | |
| Skylights | None | |
| Wall insulation | Insulated to R-0 | |
| Water Heater | Indirect tank | |
| Windows | Multiple types | |

1. To achieve the "Score with Priority Improvements" all recommended improvements in the Priority Energy Improvements section must be completed. These priority improvements have a simple payback of ten years or less.

2. Additional energy efficiency improvements may take longer than ten years to make a return on investment but can have a significant impact on the comfort, efficiency and environmental impact of your home.

3. If your home has an oil furnace it is recommended you replace it with a high efficiency electric heat pump.

4. Today's Condition represents the majority condition for that feature in the home.