



THIS HOME'S SCORE **6** OUT OF 10

THIS HOME'S ESTIMATED ENERGY COSTS

\$1,528 PER YEAR

HOME PROFILE

LOCATION:

6405 N Delaware Ave
Portland, OR 97217

YEAR BUILT:

1952

HEATED FLOOR AREA:

2,358 sq.ft.

NUMBER OF BEDROOMS:

4

ASSESSMENT

ASSESSMENT DATE:

10/24/2018

SCORE EXPIRATION DATE:

10/24/2026

ASSESSOR:

Paul DuFresne
Alpha Environmental Services

PHONE:

503-784-7872

EMAIL:

paul@
alphaenvironmental.net


LICENSE #:

152125

Flip over to learn how to improve this score and use less energy!



Home Energy Score



Official Assessment | ID# 229468

The Home Energy Score is a national rating System developed by the U.S. Department of Energy. The Score reflects the estimated energy use of a home based upon the home's structure and heating, cooling, and hot water systems. The average score is a 5. Learn more at HomeEnergyScore.gov.

HOW MUCH ENERGY IS THIS HOME LIKELY TO USE?

Electric: 11,559 kWh/yr. \$1,271
Natural Gas: 260 therms/yr. \$257
Other: \$0
Renewable Generation: (\$0)

TOTAL ENERGY COSTS PER YEAR \$1,528

How much **renewable energy** does this home generate?
 _____ kWh/yr

THIS HOME'S CARBON FOOTPRINT:



What should my home's carbon footprint be? Between now and 2030, Portlanders should reduce carbon pollution per household to 3 metric tons per year to reach our climate goals.

- Actual energy use and costs may vary based on occupant behavior and other factors.
- Estimated energy costs were calculated based on current utility prices (\$0.11/kwh for electricity; \$0.99/therm for natural gas; \$2.58/gal for heating oil; \$2.21/gal for propane).
- Carbon footprint is based only on estimated home energy use. Carbon emissions are estimated based on utility and fuel-specific emissions factors provided by the OR Department of Energy.
- Relisting 2-7 years after the assessment date requires a free reprint of the Report from us.greenbuildingregistry.com to update energy and carbon information.
- **This report meets Oregon's Home Energy Performance Score Standard and complies with Portland City Code Chapter 17.108.**

Score today:

6

Score with priority improvements:

9

Estimated energy savings with priority improvements:

\$250 PER YEAR

Estimated carbon reduction with priority improvements:

15% PER YEAR

TACKLE ENERGY WASTE TODAY!

Enjoy the rewards of a comfortable, energy efficient home that saves you money.

- Get your home energy assessment. Done!
- Choose energy improvements from the list of recommendations below.
- Select a contractor (or two, for comparison) and obtain bids.
Checkout www.energytrust.org/findacontractor or call toll free **1-866-368-7878**.
- Explore financing options at communityenergyproject.org or energytrust.org.
- Visit the following resources to learn about easy changes you can make today: communityenergyproject.org/services or energytrust.org/solutions/insulation-and-air-sealing/

PRIORITY ENERGY IMPROVEMENTS | 10 YEAR PAYBACK OR LESS ¹

| FEATURE | TODAY'S CONDITION ³ | RECOMMENDED IMPROVEMENTS |
|--------------|--------------------------------|---|
| Water Heater | Electric | When replacing, upgrade to ENERGY STAR, minimum 2.76 EF (Energy Factor) |

ADDITIONAL ENERGY RECOMMENDATIONS ²

| FEATURE | TODAY'S CONDITION ³ | RECOMMENDED IMPROVEMENTS |
|----------------------------|--------------------------------|--|
| Attic insulation | Ceiling insulated to R-25 | Insulate to R-38 or R-49 if code requires it |
| Duct sealing | Un-sealed | Reduce leakage to a maximum of 10% of total airflow |
| Envelope/Air sealing | Not professionally air sealed | Professionally air seal |
| Solar PV | N/A | Visit www.energytrust.org/solar to learn more |
| Windows | Multiple types | When replacing, upgrade to ENERGY STAR |
| Air Conditioner | N/A | |
| Basement wall insulation | Insulated to R-0 | |
| Cathedral Ceiling/Roof | None | |
| Duct insulation | Un-insulated | |
| Floor insulation | Insulated to R-11 | |
| Foundation wall insulation | N/A | |
| Heating equipment | Natural gas furnace 95% AFUE | |
| Skylights | N/A | |
| Wall insulation | Insulated to R-19 | |

1. To achieve the "Score with Priority Improvements" all recommended improvements in the Priority Energy Improvements section must be completed. These priority improvements have a simple payback of ten years or less.

2. Additional energy efficiency improvements may take longer than ten years to make a return on investment but can have a significant impact on the comfort, efficiency and environmental impact of your home.

3. If your home has an oil furnace it is recommended you replace it with a high efficiency electric heat pump.

4. Today's Condition represents the majority condition for that feature in the home.