



OREGON
DEPARTMENT OF
ENERGY

U.S. DEPARTMENT OF
ENERGY

THIS
HOME'S
SCORE **1**
OUT OF 10

THIS HOME'S ESTIMATED
ENERGY COSTS

\$2,898
PER YEAR

HOME PROFILE

LOCATION:

1550 NW Putnam Rd
Bend, OR 97703

YEAR BUILT:

2008

HEATED FLOOR AREA:

4,905 sq.ft.

NUMBER OF BEDROOMS:

4

ASSESSMENT

ASSESSMENT DATE:

10/13/2023

SCORE EXPIRATION DATE:

10/13/2031

ASSESSOR:

Scott Powers
Aurora Home Solutions Bend

PHONE:

541-728-3154

EMAIL:

aurorahomebend@
gmail.com


LICENSE #:

246372

*Flip over to learn how
to improve this score
and use less energy!*



Home Energy Score



Official Assessment | ID# 444448

The Home Energy Score is a national rating System developed by the U.S. Department of Energy. The Score reflects the estimated energy use of a home based upon the home's structure and heating, cooling, and hot water systems. The average score is a 5. Learn more at HomeEnergyScore.gov.

HOW MUCH ENERGY IS THIS HOME LIKELY TO USE?

Electric: 27,011 kWh/yr (\$0.11/kWh)..... \$2,898

Natural Gas: 0 therms/yr..... \$0

Other: \$0


Solar Generation: (\$0)

TOTAL ENERGY COSTS PER YEAR \$2,898

**How much
solar energy
does this
home
generate?**

_____ kWh/yr

THIS HOME'S CARBON FOOTPRINT:



- Actual energy use and costs may vary based on occupant behavior and other factors.
- Estimated energy costs were calculated based on current utility prices in your area.
- Carbon footprint is based only on estimated home energy use. Carbon emissions are estimated based on utility and fuel-specific emissions factors provided by the OR Department of Energy.
- This report is valid for eight years from the assessment date. A free reprint of the report is available from us.greenbuildingregistry.com with updated utility and carbon information annually.
- **This report meets Oregon's Home Energy Performance Score Standard.**

Score today:

1

Score with priority improvements:

4

Estimated energy savings with priority improvements:

\$496 PER YEAR

Estimated carbon reduction with priority improvements:

17% PER YEAR

TACKLE ENERGY WASTE TODAY!

Enjoy the rewards of a comfortable, energy efficient home that saves you money.

- Get your home energy assessment. Done!
- Choose energy improvements from the list of recommendations below.
- Select a contractor (or two, for comparison) and obtain bids. Check with your local utility for a list of contractors in your area. If a new home, discuss with the builder.
- To find out more information about the state of Oregon Home Energy score program visit: oregon.gov/energy/home-energy-score

PRIORITY ENERGY IMPROVEMENTS ¹

FEATURE	TODAY'S CONDITION ³	RECOMMENDED IMPROVEMENTS
Envelope/Air sealing	Not professionally air sealed	Professionally air seal
Heating equipment	Electric heat pump 9 HSPF	When replacing, upgrade to ENERGY STAR, minimum 9.0 HSPF (Heating Season Performance Factor)
Water Heater	Electric EF 0.92	When replacing, upgrade to ENERGY STAR, (EF \geq 2.67 or UEF \geq 2.67)

ADDITIONAL ENERGY RECOMMENDATIONS ²

FEATURE	TODAY'S CONDITION ³	RECOMMENDED IMPROVEMENTS
Attic insulation	Ceiling insulated to R-60	
Basement wall insulation	N/A	
Air Conditioner	16 SEER	
Duct insulation	Insulated	
Duct sealing	Sealed	
Wall insulation	Insulated to R-15	
Floor insulation	Insulated to R-21	
Foundation wall insulation	N/A	
Knee Wall insulation	N/A	
Skylights	N/A	
Solar PV	N/A	
Windows	Double-pane, low-E glass	

1. To achieve the "Score with Priority Improvements" all recommended improvements in the Priority Energy Improvements section must be completed. All together, these priority improvements have a simple payback of ten years or less.

2. Additional energy efficiency improvements may take longer than ten years to make a return on investment but can have a significant impact on the comfort, efficiency and environmental impact of your home.

3. Today's Condition represents the majority condition for that feature in the home.