



THIS HOME'S SCORE **5** OUT OF 10

THIS HOME'S ESTIMATED ENERGY COSTS

**\$1,922** PER YEAR

## HOME PROFILE

### LOCATION:

1136 SW Comus St  
Portland, OR 97219

### YEAR BUILT:

1993

### HEATED FLOOR AREA:

4,600 sq.ft.

### NUMBER OF BEDROOMS:

4

## ASSESSMENT

### ASSESSMENT DATE:

04/02/2018

### SCORE EXPIRATION DATE:

04/02/2026

### ASSESSOR:

Sean Kramer  
Environmental Works

### PHONE:

503-780-1036

### EMAIL:

sean@  
eworksnw.com


### LICENSE #:

185781

*Flip over to learn how to improve this score and use less energy!*



## Home Energy Score



Official Assessment | ID# 199093

The Home Energy Score is a national rating System developed by the U.S. Department of Energy. The Score reflects the estimated energy use of a home based upon the home's structure and heating, cooling, and hot water systems. The average score is a 5. Learn more at [HomeEnergyScore.gov](http://HomeEnergyScore.gov).

## HOW MUCH ENERGY IS THIS HOME LIKELY TO USE?

**Electric:** 11,749 kWh/yr. .... \$1,292  
**Natural Gas:** 636 therms/yr. .... \$630  
**Other:** ..... \$0  
**Renewable Generation:** ..... (\$0)

**TOTAL ENERGY COSTS PER YEAR \$1,922**

How much **renewable energy** does this home generate?  
 \_\_\_\_\_ kWh/yr

## THIS HOME'S CARBON FOOTPRINT:



What should my home's carbon footprint be? Between now and 2030, Portlanders should reduce carbon pollution per household to 3 metric tons per year to reach our climate goals.

- Actual energy use and costs may vary based on occupant behavior and other factors.
- Estimated energy costs were calculated based on current utility prices (\$0.11/kwh for electricity; \$0.99/therm for natural gas; \$2.58/gal for heating oil; \$2.21/gal for propane).
- Carbon footprint is based only on estimated home energy use. Carbon emissions are estimated based on utility and fuel-specific emissions factors provided by the OR Department of Energy.
- Relisting 2-7 years after the assessment date requires a free reprint of the Report from [us.greenbuildingregistry.com](http://us.greenbuildingregistry.com) to update energy and carbon information.
- **This report meets Oregon's Home Energy Performance Score Standard and complies with Portland City Code Chapter 17.108.**

Score today:

5

Score with priority improvements:

7

Estimated energy savings with priority improvements:

\$96 PER YEAR

Estimated carbon reduction with priority improvements:

6% PER YEAR

## TACKLE ENERGY WASTE TODAY!

Enjoy the rewards of a comfortable, energy efficient home that saves you money.

- Get your home energy assessment. Done!
- Choose energy improvements from the list of recommendations below.
- Select a contractor (or two, for comparison) and obtain bids.  
Checkout [www.energytrust.org/findacontractor](http://www.energytrust.org/findacontractor) or call toll free **1-866-368-7878**.
- Explore financing options at [communityenergyproject.org](http://communityenergyproject.org) or [energytrust.org](http://energytrust.org).
- Visit the following resources to learn about easy changes you can make today: [communityenergyproject.org/services](http://communityenergyproject.org/services) or [energytrust.org/solutions/insulation-and-air-sealing/](http://energytrust.org/solutions/insulation-and-air-sealing/)

## PRIORITY ENERGY IMPROVEMENTS | 10 YEAR PAYBACK OR LESS <sup>1</sup>

| FEATURE           | TODAY'S CONDITION <sup>3</sup> | RECOMMENDED IMPROVEMENTS  |
|-------------------|--------------------------------|---|
| Heating equipment | Natural gas furnace 80% AFUE   | When replacing, upgrade to ENERGY STAR                                  |
| Water Heater      | Natural gas                    | When replacing, upgrade to ENERGY STAR, minimum 0.67 EF (Energy Factor) |

## ADDITIONAL ENERGY RECOMMENDATIONS <sup>2</sup>

| FEATURE                    | TODAY'S CONDITION <sup>3</sup> | RECOMMENDED IMPROVEMENTS   |
|----------------------------|--------------------------------|--|
| Attic insulation           | Ceiling insulated to R-30      | Insulate to R-38 or R-49 if code requires it   |
| Duct sealing               | Un-sealed                      | Reduce leakage to a maximum of 10% of total airflow  |
| Envelope/Air sealing       | Not professionally air sealed  | Professionally air seal  |
| Solar PV                   | N/A                            | Visit <a href="http://www.energytrust.org/solar">www.energytrust.org/solar</a> to learn more |
| Air Conditioner            | N/A                            |  |
| Basement wall insulation   | Insulated to R-19              |  |
| Cathedral Ceiling/Roof     | Roof insulated to R-21         |  |
| Duct insulation            | Un-insulated                   |  |
| Floor insulation           | Insulated to R-19              |  |
| Foundation wall insulation | N/A                            |  |
| Skylights                  | Double-pane                    |  |
| Wall insulation            | Insulated to R-19              |  |
| Windows                    | Double-pane, low-E glass       |  |

1. To achieve the "Score with Priority Improvements" all recommended improvements in the Priority Energy Improvements section must be completed. These priority improvements have a simple payback of ten years or less.

2. Additional energy efficiency improvements may take longer than ten years to make a return on investment but can have a significant impact on the comfort, efficiency and environmental impact of your home.

3. If your home has an oil furnace it is recommended you replace it with a high efficiency electric heat pump.

4. Today's Condition represents the majority condition for that feature in the home.